

ADDENDA

**ANSI/ASHRAE/ASHE Addendum a to
ANSI/ASHRAE/ASHE Standard 170-2017**

Ventilation of Health Care Facilities

Approved by ASHRAE Standards Committee on July 31, 2020; by the ASHRAE Board of Directors on August 10, 2020; by the American Society for Health Care Engineering on July 28, 2020; and by the American National Standards Institute on September 1, 2020.

This addendum was approved by a Standing Standard Project Committee (SSPC) for which the Standards Committee has established a documented program for regular publication of addenda or revisions, including procedures for timely, documented, consensus action on requests for change to any part of the standard. Instructions for how to submit a change can be found on the ASHRAE® website (<https://www.ashrae.org/continuous-maintenance>).

The latest edition of an ASHRAE Standard may be purchased on the ASHRAE website (www.ashrae.org) or from ASHRAE Customer Service, 1791 Tullie Circle, NE, Atlanta, GA 30329-2305. E-mail: orders@ashrae.org. Fax: 678-539-2129. Telephone: 404-636-8400 (worldwide), or toll free 1-800-527-4723 (for orders in US and Canada). For reprint permission, go to www.ashrae.org/permissions.

© 2020 ASHRAE

ISSN 1041-2336



ASHRAE Standing Standard Project Committee 170

Cognizant TC: 9.6, Healthcare Facilities

SPLS Liaison: Russell C. Tharp

Michael P. Sheerin*, *Chair*

Frederick E. Granzow*, *Secretary*

David J. Anderson

George A. Augustini

Amit Bhansali

Robert Booth

Randy Brennen

Brendon J. Burley

Sarah Clock

John M. Dombrowski*

Travis R. English

Douglas S. Erickson

Jeremy P. Fauber*

Jonathan J. Flannery*

Steven D. Friedman*

Glenn Saint Aubin Gall*

Danette J. Hauck*

Caleb Haynes

Nolan Hosking

Aaron L. Johnson

Michael R. Keen

Dan Koenigshofer*

Paul R. Kondrat*

Peter H. Langowski

Roger W. Lautz*

Pavel V. Likhonin

Michael D. Locke

Stephanie J. Mages

David M. Mason

Kenneth R. Mead*

Farhad Memarzadeh*

Michael S. Meteyer*

Kenneth A. Monroe

Justin M. Opperman

Paul T. Ninomura*

Russell N. Olmsted*

Erick A. Phelps

Heather L. Platt Gullede

Benjamin D. Roseborough

Maya Salabasheva

Kevin A. Scarlett*

Charles J. Seyffer

Gordon P. Sharp*

Erica Stewart*

* Denotes members of voting status when the document was approved for publication

ASHRAE STANDARDS COMMITTEE 2020–2021

Drury B. Crawley, *Chair*

Rick M. Heiden, *Vice Chair*

Els Baert

Charles S. Barnaby

Robert B. Burkhead

Thomas E. Cappellin

Douglas D. Fick

Walter T. Grondzik

Susanna S. Hanson

Jonathan Humble

Srinivas Katipamula

Gerald J. Kettler

Essam E. Khalil

Malcolm D. Knight

Jay A. Kohler

Larry Kouma

Cesar L. Lim

James D. Lutz

Karl L. Peterman

Erick A. Phelps

David Robin

Lawrence J. Schoen

Steven C. Sill

Richard T. Swierczyna

Christian R. Taber

Russell C. Tharp

Theresa A. Weston

Craig P. Wray

Jaap Hogeling, *BOD ExO*

William F. McQuade, *CO*

Connor Barbaree, *Senior Manager of Standards*

SPECIAL NOTE

This American National Standard (ANS) is a national voluntary consensus Standard developed under the auspices of ASHRAE. *Consensus* is defined by the American National Standards Institute (ANSI), of which ASHRAE is a member and which has approved this Standard as an ANS, as “substantial agreement reached by directly and materially affected interest categories. This signifies the concurrence of more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that an effort be made toward their resolution.” Compliance with this Standard is voluntary until and unless a legal jurisdiction makes compliance mandatory through legislation.

ASHRAE obtains consensus through participation of its national and international members, associated societies, and public review.

ASHRAE Standards are prepared by a Project Committee appointed specifically for the purpose of writing the Standard. The Project Committee Chair and Vice-Chair must be members of ASHRAE; while other committee members may or may not be ASHRAE members, all must be technically qualified in the subject area of the Standard. Every effort is made to balance the concerned interests on all Project Committees.

The Senior Manager of Standards of ASHRAE should be contacted for

- interpretation of the contents of this Standard,
- participation in the next review of the Standard,
- offering constructive criticism for improving the Standard, or
- permission to reprint portions of the Standard.

DISCLAIMER

ASHRAE uses its best efforts to promulgate Standards and Guidelines for the benefit of the public in light of available information and accepted industry practices. However, ASHRAE does not guarantee, certify, or assure the safety or performance of any products, components, or systems tested, installed, or operated in accordance with ASHRAE's Standards or Guidelines or that any tests conducted under its Standards or Guidelines will be nonhazardous or free from risk.

ASHRAE INDUSTRIAL ADVERTISING POLICY ON STANDARDS

ASHRAE Standards and Guidelines are established to assist industry and the public by offering a uniform method of testing for rating purposes, by suggesting safe practices in designing and installing equipment, by providing proper definitions of this equipment, and by providing other information that may serve to guide the industry. The creation of ASHRAE Standards and Guidelines is determined by the need for them, and conformance to them is completely voluntary.

In referring to this Standard or Guideline and in marking of equipment and in advertising, no claim shall be made, either stated or implied, that the product has been approved by ASHRAE.

(This foreword is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

FOREWORD

Addendum a clarifies filtration requirements on a space-by-space basis. The filtration levels designated, and their rational basis, are included in Informative Appendix C, Table C-1. In brief, this addendum

- a. *revises requirements for filters in the body of the standard, removes Table 6.4 and adds minimum filtration efficiencies by space in Table 7.1, 8.1, 9.1 and*
- b. *adds Informative Appendix C, "Recommended Filter Efficiencies by Space Type."*

Furthermore, the presentation of this addendum has been updated from earlier public review releases for ease of the users of the standard. Some of the reflected changes include:

- a. *The name and number of spaces in Table 7.1 are modified by Addendum p, which includes a similar format of space-by-space filter assignments. The "Function of space" names in Table 7.1 have been updated and reorganized to be consistent with addendum p revisions.*
- b. *The filter assignments here supersede or replace those shown in Addendum p.*
- c. *Some line items have been removed from Table 7.1 due to addenda b and p.*
- d. *Table 7.1, 8.1, and 9.1 names have been updated to match addendum n and p revisions.*
- e. *Addendum n and p had removed previous material that is no longer shown in this addendum or sections have different numbering due to those changes.*

The change to filter requirements shifts the focus to a space-by-space-based approach, offering flexibility for users of the standard to apply the filtration selections that most rationally meets their goals for first, operational and energy costs. Filtration requirements were increased in some spaces and reduced in others, with the net effect of maintaining safe environments for occupants.

Note: In this addendum, changes to the current standard are indicated in the text by underlining (for additions) and ~~striketrough~~ (for deletions) unless the instructions specifically mention some other means of indicating the changes.

Addendum a to Standard 170-2017

Modify Section 6.4 as shown.

6.4 Filtration. Filtration of mechanically supplied air shall be provided as follows: Filter banks shall be provided in accordance with Table 6.4. Each filter bank with an efficiency of greater than MERV 12 shall be provided with an installed manometer or differential pressure measuring device that is readily accessible and provides a reading of differential static pressure across the filter to indicate when the filter needs to be changed. (For further information, see CDC [2003] in Informative Appendix B.) All of the air provided to a space shall be filtered in accordance with Table 6.4, except as otherwise indicated in Section 7.1 for spaces that allow recirculating HVAC room units.

- a. Particulate matter filters, minimum MERV-8, shall be provided upstream of the first heat exchanger surface of any air-conditioning system that combines return air from multiple rooms or introduces outdoor air.
- b. Outdoor air shall be filtered in accordance with Table 7.1, 8.1, or 9.1.
- c. Air supplied from equipment serving multiple or different spaces shall be filtered in accordance with Table 7.1, 8.1, or 9.1.
- d. Air recirculated within a room shall be filtered in accordance with Table 7.1, 8.1, or 9.1, or Section 7.1(a)(5), 8.1(a)(5), or 9.1(a)(5).
- e. The design shall include all necessary provisions to prevent moisture accumulating on filters located downstream of cooling coils and humidifiers.
- f. Minimum filter requirements shall meet the equivalent MERV rating when tested in accordance with ANSI/ASHRAE Standard 52.2.
- g. Any HEPA filter or filter MERV-14 or higher shall have sealing interface surfaces.

- h. High-efficiency particulate air (HEPA) filters are those filters that remove at least 99.97% of 0.3 micron sized particles at the rated flow in accordance with the testing methods of IEST RP CC001.3 (IEST [2005] in informative Appendix B).
- i. For spaces that do not permit air recirculated by means of room units and have a minimum filter efficiency of MERV-14 or HEPA in accordance with Table 7.1, 8.1, or 9.1, the minimum filter requirement listed in Table 7.1, 8.1, or 9.1 shall be installed downstream of all wet-air cooling coils and the supply fan.

[. . .]

~~**6.4.1 First Filtration Bank.** Filter Bank No. 1 shall be placed upstream of the heating and cooling coils such that all mixed air is filtered.~~

~~**6.4.2 Second Filtration Bank.** Filter Bank No. 2 shall be installed downstream of all wet air cooling coils and the supply fan. All second filter banks shall have sealing interface surfaces.~~

6.4.3.1 Filter Bank Blank-Off Panels. Filter bank blank-off panels shall be permanently attached to the filter bank frame, constructed of rigid materials, and have sealing surfaces equal to or greater than the filter media installed within the filter bank frame.

6.4.4.2 Filter Frames. Filter frames shall be durable and proportioned to provide an airtight fit with the enclosing ductwork. All joints between filter segments and enclosing ductwork shall have gaskets or seals to provide a positive seal against air leakage.

Modify Section 6.7.1 as shown.

6.7.1 General. Maintain the pressure relationships required in required in Tables 7.1, 8.1, and 9.1 in all modes of HVAC system operation, except as noted in the table. . . . Airstream surfaces of the air distribution system ~~downstream of Filter Bank No. 2~~ shall comply with Section 5.4 of ANSI/ ASHRAE Standard 62.1.¹² . . .

Modify Section 6.8.1 as shown.

6.8.1 General. Energy recovery systems shall be located upstream of filters required by Section 6.4 ~~Filter Bank No. 2~~. If energy recovery systems are utilized, the systems shall not allow for any amount of cross-contamination of exhaust air back to the supply airstream via purge, leakage, carryover, or transfer except as allowed in Section 6.8.3.

Modify Section 6.9(c) as shown.

6.9 Insulation and Duct Lining

[. . .]

- c. For spaces requiring a HEPA filter or minimum MERV-14 or higher filter, duct lining shall not be used in ductwork located downstream of filters ~~Filter Bank No. 2~~. Duct lining that is impervious, or with an impervious cover, may be allowed in terminal units, sound attenuators, and air distribution devices downstream of filters ~~Filter Bank No. 2~~. This lining and cover shall be factory installed.

[. . .]

Modify Section 7.1(a)(5)(iii) as shown.

7.1 General Requirements. The following general requirements shall apply for space ventilation:

- a. Spaces shall be ventilated according to Table 7.1.

[. . .]

- 5. For spaces where Table 7.1 permits air to be recirculated by room units, the portion of the minimum total air changes per hour required for a space that is greater than the minimum outdoor air changes per hour required component may be provided by recirculating room HVAC units. Such recirculating room HVAC units shall
 - i. not receive nonfiltered, nonconditioned outdoor air;
 - ii. serve only a single space; and
 - iii. provide a minimum MERV-~~6-8~~ filter for airflow passing over any surface that is designed to condense water. This filter shall be located upstream of any such cold surface, so that all of the air passing over the cold surface is filtered.

Modify Table 7.1 as shown. (Note: This addendum reflects changes previously made by Addendum p. The values in the “Minimum Filter Efficiency” column supersede or replace the values added by Addendum p.)

Table 7.1 Design Parameters—Inpatient Spaces

Function of Space (ee)	Pressure		All Room Air		Air		Unoccupied Turndown	Minimum Filter Efficiencies (cc)	Design Relative Humidity (h), %	Design Temperature (i), °F/°C
	Relationship to Adjacent Areas (m)	Minimum Outdoor ach	Exhausted Directly to Outdoors (j)	Minimum Total ach	Recirculated by Means of Room Units (a)	NR				
NURSING UNITS AND OTHER PATIENT CARE AREAS										
All anteroom (2.1-2.4.2.3) (u)	(e)	NR	Yes	10	Yes	No	Yes	8/44MERV-8	NR	NR
All room (2.1-2.4.2) (u)	Negative	2	Yes	12	Yes	No	Yes	8/44MERV-14	Max 60	70-75/21-24
Cesarean Delivery room (2.2-2.11.9) (m), (o)	Positive	4	NR	20	NR	No	Yes	8/44MERV-16	20-60	68-75/20-24
Combination AII/PE anteroom (2.2-2.2.4.5)	(e)	NR	Yes	10	Yes	No	No	8/44HEPA	NR	NR
Combination AII/PE room (2.2-2.2.4.5)	Positive	2	Yes	12	Yes	No	No	8/44HEPA (44)HEPA	Max 60	70-75/21-24
Continued care nursery (2.2-2.12.3.3)	N/R	2	N/R	6	N/R	No	Yes	8/44MERV-14	30-60	72-78/22-26
Critical care patient care station (2.2-2.6.2)	NR	2	NR	6	NR	No	Yes	8/44MERV-14	30-60	70-75/21-24
Emergency department exam/treatment room (2.2-3.1.3.6) (p)	NR	2	NR	6	NR	NR	Yes (gg)	8/44MERV-14	Max 60	70-75/21-24
Emergency department human decontamination [2.2-3.1.3.6 (8)]	Negative	2	Yes	12	Yes	No	Yes (gg)	8/44MERV-14	NR	NR
Emergency department public waiting area (2.2-3.1.3.4)	Negative	2	Yes (q)	12	Yes (q)	NR	Yes (ff)	8/44MERV-8	Max 65	70-75/21-24
Emergency department trauma/resuscitation room (2.2-3.1.3.3[6]) (c)	Positive	3	NR	15	NR	No	Yes	8/44MERV-14	20-60	70-75/21-24
Emergency service triage area (2.2-3.1.3.3)	Negative	2	Yes (q)	12	Yes (q)	NR	Yes (ff)	8/44MERV-8	Max 60	70-75/21-24
Intermediate care patient room (2.2-2.5.2) (s)	NR	2	NR	6	NR	NR	Yes	8/44MERV-14	Max 60	70-75/21-24
Labor/delivery/recovery (LDR) (2.2-2.11.3) (s)	NR	2	NR	6	NR	NR	Yes	8/44MERV-14	Max 60	70-75/21-24
Labor/delivery/recovery/postpartum (LDRP) (2.2-2.11.3) (s)	NR	2	NR	6	NR	NR	Yes	8/44MERV-14	Max 60	70-75/21-24
Laser eye room	Positive	3	NR	15	NR	No	Yes	8/44MERV-14	20-60	70-75/21-24
Neonatal intensive care (2.2-2.10.2)	Positive	2	NR	6	NR	No	Yes	8/44MERV-14	30-60	72-78/22-26
Newborn nursery (2.2-2.12.3.1)	NR	2	NR	6	NR	No	Yes	8/44MERV-14	30-60	72-78/22-26
Nourishment area or room (2.1-2.6.7)	NR	NR	NR	2	NR	NR	Yes	8/44MERV-8	NR	NR

Note: NR = no requirement

Table 7.1 Design Parameters—Inpatient Spaces (Continued)

Function of Space (ee)	Pressure Relationship to Adjacent Areas (n)		Minimum Outdoor ach		All Room Air		Recirculated by Means of Room Units (a)		Unoccupied Turndown	Minimum Filter Efficiencies (cc)	Design Relative Humidity (k), %	Design Temperature (l), °F/°C
	Minimum ach	Exhausted Directly to Outdoors (j)	Minimum Total ach	Yes	No	Yes	No					
Nursery workroom (2.2-2.12.6.3)	NR	NR	6	NR	NR	No	NR	Yes	8/44MERV-8	Max 60	72-78/22-26	
Operating room (2.2-3.3.2) (m), (o)	Positive	NR	20	NR	NR	No	NR	Yes	8/44MERV-16 (hh)	20-60	68-75/20-24	
Operating/surgical cystoscopic rooms (m), (o)	Positive	NR	20	NR	NR	No	NR	Yes	8/44MERV-16	20-60	68-75/20-24	
Patient care area corridor	NR	NR	2	NR	NR	NR	NR	Yes	8/44MERV-14	NR	NR	
Patient room (2.1-2.2)	NR	NR	2	NR	NR	NR	NR	Yes	8/44MERV-14	Max 60	70-75/21-24	
Patient toilet room (2.1-2.2.6)	Negative	NR	10	Yes	NR	No	NR	Yes (ff)	8/44MERV-8	NR	NR	
PE anteroom (t)	(e)	NR	10	NR	NR	No	NR	No	8/44HEPA	NR	NR	
Phase I PACU and Phase II recovery (2.2-3.3.4.3 and 2.2-3.3.4.4)	NR	NR	2	NR	NR	No	NR	Yes	8/44MERV-14	20-60	70-75/21-24	
Procedure room (3.7-3.2) (o), (d)	Positive	NR	3	NR	NR	No	NR	Yes	13/44MERV-14	20-60	70-75/21-24	
Protective environment room (2.2-2.2.4.4) (t)	Positive	NR	2	NR	NR	No	NR	No	8/44HEPA (44)HEPA	Max 60	70-75/21-24	
Radiology waiting rooms	Negative	NR	2	Yes (q), (w)	NR	NR	NR	Yes (ff)	8/44MERV-8	Max 60	70-75/21-24	
Seclusion room (2.1-2.4.3)	NR	NR	2	NR	NR	NR	NR	Yes	8/44MERV-14	Max 60	70-75/21-24	
Sterile processing room (2.2-3.3.6.13)	NR	NR	2	NR	NR	No	NR	Yes	8/44MERV-8 (gg)	NR	NR	
Treatment room (p)	NR	NR	2	NR	NR	NR	NR	Yes	8/44MERV-8	20-60	70-75/21-24	
Wound intensive care (burn unit)	NR/Positive	NR	2	NR	NR	No	NR	Yes	8/44HEPA	40-60	70-75/21-24	
BEHAVIORAL AND MENTAL HEALTH FACILITIES (k)												
Patient bedroom, resident room (2.5-2.2.2)	NR	NR	2	NR	NR	NR	NR	Yes	8/44MERV-14	NR	NR	NR
Seclusion room (2.5-2.2.4.3)	NR	NR	4	NR	NR	NR	NR	Yes	8/44MERV-14	NR	NR	NR
DIAGNOSTIC AND TREATMENT												
Bronchoscopy, sputum collection, and pentamidine administration	Negative	NR	2	Yes	NR	No	NR	Yes	8/44MERV-14	NR	NR	68-73/20-23
Dialysis treatment area	NR	NR	2	NR	NR	NR	NR	Yes	8/44MERV-8	NR	NR	72-78/22-26
Dialyzer reprocessing room	Negative	NR	10 (bb)	Yes	NR	No	NR	Yes (ff)	8/44MERV-8	NR	NR	NR
ECT procedure room (2.5-3.4.2.2)	NR	NR	2	NR	NR	NR	NR	Yes	8/44MERV-8	Max 60	72-78/22-26	
Endoscope cleaning	Negative	NR	2	Yes	NR	No	NR	No	8/44MERV-8	NR	NR	NR

Note: NR = no requirement

Table 7.1 Design Parameters—Inpatient Spaces (Continued)

Function of Space (ee)	Pressure			All Room Air			Design		
	Relationship to Adjacent Areas (n)	Minimum Outdoor ach	Minimum Total ach	Exhausted Directly to Outdoors (j)	Air Recirculated by Means of Room Units (a)	Unoccupied Turndown	Minimum Filter Efficiencies (cc)	Relative Humidity (k), %	Design Temperature (l), °F/°C
Gastrointestinal endoscopy procedure room (x)	NR	2	6	NR	No	Yes	8/44 MERV-8	20–60	68–73/20–23
General examination room	NR	2	4	NR	NR	Yes	8/44 MERV-8	Max 60	70–75/21–24
Hydrotherapy	Negative	2	6	NR	NR	Yes	8/44 MERV-8	NR	72–80/22–27
Imaging (diagnostic and treatment)	NR	2	6	NR	NR	Yes	8/44 MERV-8	Max 60	72–78/22–26
Interventional and intraoperative MRI procedure room (2.2–3.5.2)	Positive	3	15	NR	No	Yes	8/44 MERV-14	Max 60	70–75/21–24
Interventional imaging procedure room (2.2–3.5.2)	Positive	3	15	NR	No	Yes	8/44 MERV-14	Max 60	70–75/21–24
Medication room	NR	2	4	NR	NR	Yes	8/44 MERV-8	Max 60	70–75/21–24
Nuclear medicine hot lab	Negative	NR	6	Yes	No	Yes (ff)	8/44 MERV-8	NR	70–75/21–24
Nuclear medicine procedure room (2.2–3.6.1)	Negative	2	6	Yes	NR	Yes	8/44 MERV-14	NR	70–75/21–24
Physical therapy	Negative	2	6	NR	NR	Yes	8/44 MERV-8	Max 65	72–80/22–27
Special examination room (aa)	NR	2	6	NR	NR	Yes	8/44 MERV-14 (ii)	Max 60	70–75/21–24
Treatment room	NR	2	6	NR	NR	Yes	8/44 MERV-8	Max 60	70–75/21–24
PATIENT SUPPORT FACILITIES									
Bedpan room	Negative	NR	10	Yes	No	No	8/44 MERV-8	NR	NR
Environmental services room (2.1–4.3.8.12)	Negative	NR	10	Yes	No	No	8/44 MERV-8	NR	NR
Food and supply storage (2.1–4.3.8.11)	NR	NR	2	NR	No	No	8/44 MERV-8	NR	72–78/22–26
Food preparation areas (i) (2.1–4.3.2)	NR	2	10	NR	No	Yes	8/44 MERV-8	NR	72–78/22–26
Laboratory work area, bacteriology (f), (v)	Negative	2	6	Yes	NR	Yes	13/44 MERV-8	NR	70–75/21–24
Laboratory work area, biochemistry (f), (v)	Negative	2	6	Yes	NR	Yes	13/44 MERV-8	NR	70–75/21–24
Laboratory work area, cytology (f), (v)	Negative	2	6	Yes	NR	Yes	13/44 MERV-8	NR	70–75/21–24
Laboratory work area, general (f), (v)	Negative	2	6	NR	NR	Yes	13/44 MERV-8	NR	70–75/21–24
Laboratory work area, glasswashing (f)	Negative	2	10	Yes	NR	Yes	13/44 MERV-8	NR	70–75/21–24
Laboratory work area, histology (f), (v)	Negative	2	6	Yes	NR	Yes	13/44 MERV-8	NR	70–75/21–24
Laboratory work area, media transfer (f), (v)	Positive	2	4	NR	NR	Yes	13/44 MERV-8	NR	70–75/21–24
Laboratory work area, microbiology (f), (v)	Negative	2	6	Yes	NR	Yes	13/44 MERV-8	NR	70–75/21–24

Note: NR = no requirement

Table 7.1 Design Parameters—Inpatient Spaces (Continued)

Function of Space (ee)	Pressure		All Room Air		Recirculated by		Design	
	Relationship to Adjacent Areas (n)	Minimum Outdoor ach	Exhausted Directly to Outdoors (j)	Means of Room Units (a)	Unoccupied Turndown	Minimum Filter Efficiencies (cc)	Relative Humidity (k), %	Design Temperature (l), °F/°C
Laboratory work area, nuclear medicine (f), (v)	Negative	2	Yes	NR	Yes	13 NR 1 MERV-8	NR	70–75/21–24
Laboratory work area, pathology (f), (v)	Negative	2	Yes	NR	No	13 NR 1 MERV-8	NR	70–75/21–24
Laboratory work area, serology (f), (v)	Negative	2	Yes	NR	Yes	13 NR 1 MERV-8	NR	70–75/21–24
Laboratory work area, sterilizing (f)	Negative	2	Yes	NR	Yes	13 NR 1 MERV-8	NR	70–75/21–24
Pharmacy Services: Pharmacy Areas (b) (2.1–4.2.2)	Positive	2	NR	NR	Yes	8 44MERV-8	Max 60	70–75/21–24
Toilet room (2.1–4.3.9.1)	Negative	NR	Yes	No	Yes	8 NR 2 MERV-8	NR	72–78/22–26
Warewashing (2.1–4.3.4) (r)	Negative	NR	Yes	No	Yes	8 NR 2 MERV-8	NR	NR
GENERAL SUPPORT FACILITIES: STERILE PROCESSING								
Clean assembly/workroom (2.1–5.1.2) (z)	Positive	2	NR	No	No	8 44MERV-8 (egg)	Max 60	68–73/20–23
Soiled workroom/decontamination room (2.1–5.1.3) (z)	Negative	2	Yes	No	No	8 NR 2 MERV-8	NR	60–73/16–23
Sterile storage room (clean/sterile medical/ surgical supplies (2.1–5.1.4.1) (z)	Positive	2	NR	NR	No	8 44MERV-8 (egg)	Max 60	Max 75/24
OTHER GENERAL SUPPORT FACILITIES								
Autopsy room (2.1–5.7.2.2)	Negative	2	Yes	No	No	8 44MERV-8	NR	68–75/20–24
Clean linen storage room (2.1–5.2.3.2)	Positive	NR	NR	NR	Yes	8 44MERV-8	NR	72–78/22–26
Hazardous material storage	Negative	2	Yes	No	No	8 NR 2 MERV-8	NR	NR
Laundry, processing room (2.1–5.2.2 [2])	Negative	2	Yes	No	No	8 NR 2 MERV-8	NR	NR
Linen and refuse chute room (2.1–5.4.1.4)	Negative	NR	Yes	No	No	8 NR 2 MERV-8	NR	NR
Nonrefrigerated body-holding room (h)	Negative	NR	Yes	No	No	13 NR 1 MERV-8	NR	70–75/21–24
Regulated waste holding spaces (2.1–5.4.1.3)	Negative	NR	Yes	No	No	8 NR 2 MERV-8	NR	NR
Toilet (2.1–5.2.4.1)	Negative	NR	Yes	No	Yes	8 NR 2 MERV-8	NR	NR
SUPPORT AREAS FOR NURSING UNITS AND OTHER PATIENT CARE AREAS								
Clean supply room (2.1–2.6.9.2)	Positive	NR	NR	NR	Yes	8 44MERV-8	NR	NR
Clean workroom (2.1–2.6.9.1)	Positive	2	NR	NR	Yes	8 44MERV-8	NR	NR
Soiled workroom or soiled holding (2.1–2.6.10)	Negative	2	Yes	No	No	8 44MERV-8	NR	NR

Note: NR = no requirement

Normative Notes for Table 7.1:

[. . .]

- b. Pharmacy compounding areas may have additional air change, ~~and differential pressure, and filtering~~ requirements beyond the minimum of this table, depending on the type of pharmacy, the regulatory requirements (which may include adoption of USP-797), the associated level of risk of the work (**Informative Note:** See USP [2017] in Appendix B), and the equipment used in the spaces. Minimum efficiency of filters for any space where compounding occurs shall be determined by the applicable USP standard (USP 795, USP 797, or USP 800).

[. . .]

- cc. Table entries are the minimum filter efficiencies required for the space. Refer to Section 6.4 of this document for further clarification of filtration requirements. ~~The first table entry is the minimum filter efficiency for Filter Bank No. 1. The second table entry (after the slash) is the minimum filter efficiency for Filter Bank No. 2.~~ The minimum efficiency reporting value (MERV) is based on the method of testing described in ANSI/ASHRAE Standard 52.2, *Method of Testing General Ventilation Air-Cleaning Devices for Removal Efficiency by Particle Size* ([ASHRAE 2012] in Informative Appendix B).
- gg. Minimum MERV-14 filters shall be required for spaces where sterile equipment is packed into sterile packages. Spaces where sterile products are stored but not packed shall not be required to have MERV-14 filters.
- hh. See also Section 7.4.1(c).
- ii. A minimum MERV-8 filter may be utilized for this space in lieu of a minimum MERV-14 filter if all room air is exhausted directly to the outdoors and the pressure relationship to adjacent areas is kept negative. If a filter rated less than MERV-14 is utilized, the space shall be considered "Negative" with regards to the table and must comply with all other requirements for negative spaces within the standard.
-

Modify Section 7.2.2 as shown.

7.2.2 Protective Environment (PE) Rooms. Ventilation for PE rooms shall meet the following requirements:

[. . .]

- c. Air distribution patterns within the protective environment room shall conform to the following:
1. Supply air diffusers shall be above the patient bed unless it can be demonstrated that such a location is not practical. Diffuser design shall limit air velocity at the patient bed to reduce patient discomfort. (See ASHRAE Standard 55 [2013] in Informative Appendix B.)
 2. Return/exhaust grilles or registers shall be located near the patient room door.
 3. HEPA filters shall be located in the air terminal device.

Exception to 7.2.2(c): For common systems serving more than one protective environment space and where more than 75% of airflow serves protective environment spaces, HEPA filters may be located in the air-handling unit in a position downstream of all cooling and heating equipment.

[. . .]

Modify Section 7.4.1 as shown.

7.4.1 Operating Rooms, Operating/Surgical Cystoscopic Rooms, and Caesarean Delivery Rooms. These rooms shall be maintained at a positive pressure with respect to all adjoining spaces at all times. A pressure differential shall be maintained at a value of at least +0.01 in. wc (2.5 Pa). Each room shall have individual temperature control. These rooms shall be provided with a primary supply diffuser array that is designed as follows:

[. . .]

- c. In operating rooms designated for orthopedic procedures, transplants, neurosurgery, or dedicated burn unit procedures, HEPA filters shall be provided.

[. . .]

Modify Section 8.1(a)(5)(iii) as shown.

8.1 General Requirements. The following general requirements shall apply for space ventilation:

a. Spaces shall be ventilated according to Table 8.1.

[. . .]

5. For spaces where Table 8.1 permits air to be recirculated by room units, the portion of the minimum total air changes per hour required for a space that is greater than the minimum outdoor air changes per hour required component may be provided by recirculating room HVAC units. Such recirculating room HVAC units shall
 - i. not receive nonfiltered, nonconditioned outdoor air;
 - ii. serve only a single space; and
 - iii. provide a minimum ~~MERV-6~~⁸ filter for airflow passing over any surface that is designed to condense water. This filter shall be located upstream of any such cold surface, so that all of the air passing over the cold surface is filtered.

[. . .]

Modify Table 8.1 as shown.

Modify Section 8.3.1 as shown.

Table 8.1 Design Parameters for Outpatient-Specific Spaces

Function of Space (f)	Pressure Relationship to Adjacent Areas (n)			All Room Air		Minimum Filter Recirculated by Means of Room Units (a)	Minimum Filter Efficiencies (c)	Design Relative Humidity (k), %	Design Temperature (l), °F/°C
	(n)	Minimum Outdoor ach	Minimum Total ach	Exhausted Directly to Outdoors (j)	Air Recirculated by Units (a)				
COMMON SPACES IN OUTPATIENT FACILITIES									
All anteroom (i) (3.1-3.4.3)	(e)	NR	10	Yes	No	7 NR	NR MERV-8	NR	NR
All room (i) (3.1-3.4.2)	Negative	2	12	Yes	No	7 NR	NR MERV-8	Max 60	70-75/21-24
Bronchoscopy, sputum collection, and pentamidine administration (n)	Negative	2	12	Yes	No	7 NR	NR MERV-14	NR	68-73/20-23
Clean supply storage (3.1-3.6.9)	Positive	2	4	NR	NR	7 NR	NR MERV-8	Max 60	72-78/22-26
Emergency waiting rooms	Negative	2	12	Yes (q)	NR	7 NR	NR MERV-8	Max. 65	70-75/21-24
Environmental services room (3.1-5.5.1)	Negative	NR	10	Yes	No	7 NR	NR MERV-8	NR	NR
General-purpose examination/observation room (3.1-3.2.2)	NR	2	4	NR	NR	7 NR	NR MERV-8	Max 60	70-75/21-24
Laboratory testing/work area if in a separate dedicated room (3.1-4.1.2)	Negative	2	6	Yes	NR	7 NR	NR MERV-8	NR	70-75/21-24
Medical waste holding spaces (3.1-5.4.1.3)	Negative	2	10	Yes	No	7 NR	NR MERV-8	NR	NR
Medication preparation room programmed to compound sterile preparations (b) (3.1-3.6.6.2)	Positive	2	4	NR	NR	7 HEPA (e) MERV-8		NR	NR
Soiled holding room (3.1-3.6.10)	Negative	2	6	Yes	No	7 NR	NR MERV-8	NR	72-78/22-26
Special-purpose examination room (3.1-3.2.3)	NR	2	6	NR	NR	7 NR	NR MERV-14 (w)	Max 60	70-75/21-24
SPACES SPECIFIC TO PARTICULAR OUTPATIENT FACILITIES									
Cancer treatment area (p) (3.6-3.2)	NR	2	6	NR	NR	7 NR	NR MERV-8	Max 60	70-75/21-24
Diagnostic imaging waiting area (3.5-6.1.3.2) (g)	Negative	2	12	Yes (q), (r)	NR	7 NR	NR MERV-8	Max 60	70-75/21-24
ECT procedure room (p) (3.11-3.3.2.2)	NR	2	4	NR	NR	7 NR	NR MERV-8	Max 60	70-75/21-24
Endoscopy procedure room (h) (3.9-3.2.2)	NR	2	6	NR	No	7 NR	NR MERV-8	Max 60	68-73/20-23
Freestanding urgent care facility procedure room (3.5-3.2.2)	Positive	2	6	NR	No	7 NR	NR MERV-8	NR	70-75/21-24
Instrument processing room (3.9-5.1)	Negative	2	10	Yes	No	7 NR	NR MERV-8 (s)	NR	NR
Office-based procedure room (p) (3.8-3.1)	NR	2	4	NR	NR	7 NR	NR MERV-8	Max 60	70-75/21-24
Outpatient surgical facility operating room (m), (o) (3.7-3.3)	Positive	4	20	NR	No	7 4MERV-16 (v)	20-60	20-60	68-75/20-24
Outpatient surgical facility procedure room (o), (d) (3.7-3.2)	Positive	3	15	NR	No	7 NR	NR MERV-14	20-60	70-75/21-24
Postoperative recovery area (3.7-3.4.3)	NR	2	6	NR	No	7 NR	NR MERV-8	Max 60	70-75/21-24
Postprocedure recovery area (u) (3.9-3.3)	NR	2	2	NR	NR	7 NR	NR MERV-8	Max 60	70-75/21-24
Preprocedure patient care area (t) (3.9-3.3)	NR	2	2	NR	NR	7 NR	NR MERV-8	Max 60	70-75/21-24

Note: NR = no requirement

Normative Notes for Table 8.1:

[. . .]

- b. ~~Pharmacy compounding areas may have additional air change, and differential pressure, and filtering requirements beyond the minimum of this table, depending on the type of pharmacy, the regulatory requirements (which may include adoption of USP 797), the associated level of risk of the work~~ **(Informative Note:** See USP [2017] in Appendix B), and the equipment used in the spaces. Minimum efficiency of filters for any space where compounding occurs shall be determined by the applicable USP standard (USP 795, USP 797, or USP 800).

[. . .]

- s. ~~As an alternative to the requirement for HEPA filters in Filter Bank No. 2, MERV-14 rated filters may be used in Filter Bank No. 2 if a tertiary terminal HEPA filter is provided for this space. High efficiency particulate air (HEPA) filters are those filters that remove at least 99.97% of 0.3 micron-sized particles at the rated flow in accordance with the testing methods of IEST RP-CC001.3~~ **Informative Note:** See IEST [2005] in Appendix B. Minimum MERV-14 filters shall be required for spaces where sterile equipment is packed into sterile packages. Spaces where sterile products are stored but not packed shall not be required to have MERV-14 filters.

[. . .]

- v. See also Section 8.4.1(c).

- w. A minimum MERV-8 filter may be utilized for this space in lieu of a minimum MERV-14 filter if all room air is exhausted directly to the outdoors and the pressure relationship to adjacent areas is kept negative. If a filter rated less than MERV-14 is utilized, the space shall be considered “Negative” with regards to the table and must comply with all other requirements for negative spaces within the standard.

- x. Examination rooms programmed for use by patients with undiagnosed gastrointestinal symptoms, undiagnosed respiratory symptoms, or undiagnosed skin symptoms.
-

8.3.1 Operating Rooms, Operating/Surgical Cystoscopic Rooms, and Cesarean Delivery Rooms. These rooms shall be maintained at a positive pressure with respect to all adjoining spaces at all times. A pressure differential shall be maintained at a value of at least +0.01 in. wc (2.5 Pa). Each room shall have individual temperature control. These rooms shall be provided with a primary supply diffuser array that is designed as follows:

[. . .]

- c. In operating rooms designated for orthopedic procedures, transplants, neurosurgery, or dedicated burn unit procedures, HEPA filters shall be provided.

[. . .]

Modify Table 9.1 as shown.

Modify Section 11 as shown.

Table 9.1 Design Parameters for Residential Health, Care, and Support-Specific Spaces

Function of Space	Pressure Relationship to Adjacent Areas (f)		Minimum Total ach	Exhausted Directly to Outdoors (j)		Air Recirculated by Means of Room Units (a)	Minimum Filter Efficiencies (m)	Design Relative Humidity (k), %	Design Temperature (l), °F/°C
	Minimum Outdoor ach	Minimum Total ach		Yes	No				
NURSING HOMES									
All room (c)	Negative	2	12	Yes	No		13 NR MERV-14	Max 60	70-75/21-24
All anteroom (c)	(e)	NR	10	Yes	No		13 NR MERV-8	NR	NR
Occupational therapy	NR	2	6	NR	NR		13 NR MERV-8	NR	70-75/21-24
Physical therapy	Negative	2	6	NR	NR		13 NR MERV-8	NR	70-75/21-24
Resident gathering/activity/dining	NR	4	4	NR	NR		13 NR MERV-8	NR	70-75/21-24
Resident room	NR	2	2	NR	NR		13 NR MERV-14	NR	70-75/21-24
Resident unit corridor	NR	NR	4	NR	NR		13 NR MERV-8	NR	NR
Toilet/bathing room	Negative	NR	10	Yes	No		13 NR MERV-8	NR	70-75/21-24
ASSISTED LIVING FACILITIES									
Resident gathering/activity/dining	NR	NR	NR	NR	NR		7 NR MERV-8	NR	NR
Resident room	NR	NR	NR	NR	NR		7 NR MERV-8	NR	NR
Resident unit corridor	NR	NR	NR	NR	NR		7 NR MERV-8	NR	NR
Toilet/bathing room	NR	NR	NR	NR	NR		7 NR MERV-8	NR	NR
HOSPICE FACILITIES									
All room (c)	Negative	2	12	Yes	No		13 NR MERV-14	Max 60	70-75/21-24
All anteroom (c)	(e)	NR	10	Yes	No		13 NR MERV-8	NR	NR
Resident room	NR	2	2	NR	NR		13 NR MERV-8	NR	70-75/21-24
Resident unit corridor	NR	NR	4	NR	NR		13 NR MERV-8	NR	NR
Toilet/bathing room	Negative	NR	10	Yes	No		13 NR MERV-8	NR	70-75/21-24
RADIOLOGY									
X-ray (diagnostic and treatment)	NR	2	6	NR	NR		13 NR MERV-8	Max 60	72-78/22-26
SERVICE									
Clean linen storage	Positive	NR	2	NR	NR		7 NR MERV-8	NR	72-78/22-26
Dietary storage	NR	NR	2	NR	No		7 NR MERV-8	NR	72-78/22-26
Food preparation center (i)	NR	2	10	NR	No		7 NR MERV-8	NR	72-78/22-26
Janitor's closet	Negative	NR	10	Yes	No		7 NR MERV-8	NR	
Laundry, general	Negative	2	10	Yes	No		7 NR MERV-8	NR	
Linen and trash chute room	Negative	NR	10	Yes	No		7 NR MERV-8	NR	
Soiled linen sorting and storage	Negative	NR	10	Yes	No		7 NR MERV-8	NR	
Warewashing	Negative	NR	10	Yes	No		7 NR MERV-8	NR	
SUPPORT SPACE									
Clean utility	Positive	2	4	NR	NR		7 NR MERV-8(g)	NR	NR
Hazardous material storage	Negative	2	10	Yes	No		7 NR MERV-8	NR	NR
Soiled utility or soiled holding	Negative	2	10	Yes	No		7 NR MERV-8	NR	NR

Note: NR = No requirement

Normative Notes for Table 9.1:

[. . .]

- g. ~~Not used.~~ Minimum MERV-14 filters shall be required for spaces where sterile equipment is packed into sterile packages. Spaces where sterile products are stored but not packed shall not be required to have MERV-14 filters.

[. . .]

- l. Table entries are the minimum filter efficiencies required for the space. Refer to Section 6.4 of this document for further clarification of filtration requirements. ~~The first table entry is the minimum filter efficiency for Filter Bank No. 1. The second table entry (after the slash) is the minimum filter efficiency for Filter Bank No. 2.~~ The minimum efficiency reporting value (MERV) is based on the method of testing described in ANSI/ASHRAE Standard 52.2 (**Informative Note:** ASHRAE [2012] in Appendix B).
-

11. NORMATIVE REFERENCES

14. ISO. 2016. ISO 16890-1, *Air filters for general ventilation—Part 1: Technical specifications, requirements and classification system based upon particulate matter efficiency (ePM)*. Geneva, Switzerland: International Organization for Standardization.

Modify Informative Appendix A as shown.

A1. O&M IN HEALTH CARE FACILITIES

The following operations and maintenance procedures are recommended for health care facilities.

A1.1 Operating Rooms

- a. Each operating room should be tested for positive pressure semi-annually or on an effective preventative maintenance schedule.
- b. ~~When HEPA filters are present within the diffuser of operating rooms, the filter should be replaced based on pressure drop.~~
- eb. Operating and caesarean delivery room ventilation systems shall operate at all times, except during maintenance and conditions requiring shutdown by the building's fire alarm system.

A1.2 Protective Environment (PE) Rooms. PE rooms should remain under positive pressure with respect to all adjoining rooms whenever an immunocompromised patient is present. PE rooms should be tested for positive pressure daily when an immunocompromised patient is present. ~~When HEPA filters are present within the diffuser of protective environment rooms, the filter should be replaced based on pressure drop.~~

A1.3 Airborne Infection Isolation (AII) Rooms. AII rooms should remain under negative pressure relative to all adjoining rooms whenever an infectious patient is present. They should be tested for negative pressure daily whenever an infectious patient is present.

A1.4 Filters. ~~Final filters and filter frames should be visually inspected for pressure drop and for bypass monthly. Filters should be replaced based on pressure drop with filters that provide the efficiencies specified in Table 6.4. All filters and air cleaning devices shall be replaced or maintained per manufacturer recommendations.~~

Modify Informative Appendix B as shown.

INFORMATIVE APPENDIX B INFORMATIVE REFERENCES AND BIBLIOGRAPHY

[. . .]

ASHRAE. ~~2010~~2016. ANSI/ASHRAE Standard 62.1, *Ventilation for Acceptable Indoor Air Quality*. Atlanta: ASHRAE.

ASHRAE 2016. ANSI/ASHRAE Standard 62.2, *Ventilation and Acceptable Indoor Air Quality in Residential Buildings*. Atlanta: ASHRAE.

Add Informative Appendix C.

(This appendix is not part of this standard. It is merely informative and does not contain requirements necessary for conformance to the standard. It has not been processed according to the ANSI requirements for a standard and may contain material that has not been subject to public review or a consensus process. Unresolved objectors on informative material are not offered the right to appeal at ASHRAE or ANSI.)

INFORMATIVE APPENDIX C
RECOMMENDED FILTER EFFICIENCIES BY SPACE TYPE

Spaces in Table 7-1 of this standard have filter efficiencies assigned based on Table C-1. This table is provided here for information to allow users to understand the intent of the filter assignments and make engineering judgments on spaces not specifically named in the standard.

Table C-1 Recommended Filter Efficiencies by Space Type

Level	Space Category	Filter Efficiency Recommendations (a)(b)
I	<ul style="list-style-type: none"> • <u>Primarily exhausted space (e.g., restrooms, janitor's rooms)</u> • <u>Any human-occupied space</u> • <u>Any room, inpatient or outpatient, where a patient stays less than 6 hours including waiting rooms</u> • <u>Laboratories</u> • <u>Resident rooms in assisted living or hospice</u> • <u>Storage of packaged sterile material, clean linen, or pharmaceuticals (c)</u> • <u>Treatment rooms, endoscopy procedure room</u> • <u>Dirty side of decontamination process</u> 	<u>MERV 8 (equivalent to ASHRAE 62.1 or Standard 62.2)</u>
II	<ul style="list-style-type: none"> • <u>Inpatient spaces, including medical-surgical, airborne isolation (d)</u> • <u>Special exam room for suspect airborne cases, emergency department exam rooms (e)</u> • <u>Resident room in a skilled nursing area</u> • <u>Workroom for packing of sterile materials</u> • <u>CT or MRI procedure, interventional radiology (including biopsy), or bronchoscopy</u> • <u>ER procedure or trauma room</u> 	<u>MERV14 (f)(g)</u>
III	<ul style="list-style-type: none"> • <u>Operating room (h)</u> 	<u>MERV16 (f)</u>
IV	<ul style="list-style-type: none"> • <u>Operating room designated for orthopedic, transplants, neurosurgery, or dedicated burn unit procedures</u> • <u>Protective environments, including burn units</u> 	<u>HEPA</u>

Notes:

- a. Where listed, MERV rating is assumed to be non-degrading
- b. Transfer air due to differences in pressure between spaces may be unfiltered.
- c. Pharmacy compounding spaces are not covered in this table. Follow <USP>795, <USP> 797, or <USP> 800 as applicable.
- d. Does not include recirculated air. Air recirculated in an Airborne Isolation room requires HEPA filters.
- e. Air from spaces where suspected airborne cases may be treated or examined should be filtered at level II prior to re-circulation to other spaces. If exhausted, supply air filtration may be level I.
- f. Minimum MERV rating of the highest efficiency filter in the air stream.
- g. Filter efficiency if supply air is used; Not intended to exclude natural ventilation if otherwise allowed.
- h. An optional risk assessment, with the user group may indicate a need to increase from Level III to Level IV.

POLICY STATEMENT DEFINING ASHRAE'S CONCERN FOR THE ENVIRONMENTAL IMPACT OF ITS ACTIVITIES

ASHRAE is concerned with the impact of its members' activities on both the indoor and outdoor environment. ASHRAE's members will strive to minimize any possible deleterious effect on the indoor and outdoor environment of the systems and components in their responsibility while maximizing the beneficial effects these systems provide, consistent with accepted Standards and the practical state of the art.

ASHRAE's short-range goal is to ensure that the systems and components within its scope do not impact the indoor and outdoor environment to a greater extent than specified by the Standards and Guidelines as established by itself and other responsible bodies.

As an ongoing goal, ASHRAE will, through its Standards Committee and extensive Technical Committee structure, continue to generate up-to-date Standards and Guidelines where appropriate and adopt, recommend, and promote those new and revised Standards developed by other responsible organizations.

Through its *Handbook*, appropriate chapters will contain up-to-date Standards and design considerations as the material is systematically revised.

ASHRAE will take the lead with respect to dissemination of environmental information of its primary interest and will seek out and disseminate information from other responsible organizations that is pertinent, as guides to updating Standards and Guidelines.

The effects of the design and selection of equipment and systems will be considered within the scope of the system's intended use and expected misuse. The disposal of hazardous materials, if any, will also be considered.

ASHRAE's primary concern for environmental impact will be at the site where equipment within ASHRAE's scope operates. However, energy source selection and the possible environmental impact due to the energy source and energy transportation will be considered where possible. Recommendations concerning energy source selection should be made by its members.

ASHRAE · 1791 Tullie Circle NE · Atlanta, GA 30329 · www.ashrae.org

About ASHRAE

Founded in 1894, ASHRAE is a global professional society committed to serve humanity by advancing the arts and sciences of heating, ventilation, air conditioning, refrigeration, and their allied fields.

As an industry leader in research, standards writing, publishing, certification, and continuing education, ASHRAE and its members are dedicated to promoting a healthy and sustainable built environment for all, through strategic partnerships with organizations in the HVAC&R community and across related industries.

To stay current with this and other ASHRAE Standards and Guidelines, visit www.ashrae.org/standards, and connect on LinkedIn, Facebook, Twitter, and YouTube.

About ASHE

The American Society for Health Care Engineering (ASHE) of the American Hospital Association is a trusted professional resource that provides education, regulatory guidance, networking, advocacy representation, and professional development for our members. ASHE is committed to our members, the facilities they build and maintain, and the patients they serve.

For more information, visit ashe.org.

Visit the ASHRAE Bookstore

ASHRAE offers its Standards and Guidelines in print, as immediately downloadable PDFs, and via ASHRAE Digital Collections, which provides online access with automatic updates as well as historical versions of publications. Selected Standards and Guidelines are also offered in redline versions that indicate the changes made between the active Standard or Guideline and its previous version. For more information, visit the Standards and Guidelines section of the ASHRAE Bookstore at www.ashrae.org/bookstore.

IMPORTANT NOTICES ABOUT THIS STANDARD

To ensure that you have all of the approved addenda, errata, and interpretations for this Standard, visit www.ashrae.org/standards to download them free of charge.

Addenda, errata, and interpretations for ASHRAE Standards and Guidelines are no longer distributed with copies of the Standards and Guidelines. ASHRAE provides these addenda, errata, and interpretations only in electronic form to promote more sustainable use of resources.